




| * TEST REPORT * | | | | | | |
|---|-----------------|--------------------------|---|-------------------|-------|---|
| Name & Address of Customer: | | Customer Reference No. | No: 321/AZ/27 Dated: 20/04/2024 | | | |
| MAA DURGAVATI PUBLIC SCHOOL, MAHUJA NEWADA, MARTINGANJ, AZAMGARH, U.P. | | Sample Submitted by | REETA DEVI | | | |
| | | Date of Sample Receipt | 20/04/2024 | | | |
| | | Analysis Starting Date | 20/04/2024 | | | |
| | | Analysis completion Date | 25/04/2024 | | | |
| Discipline: Chemical Testing | | Group: Water | | | | |
| Test Report No.: | RWTL/ 331/LT-31 | Date of Issue: | 25/04/2024 | | | |
| Registration no.: | RWTL/ 331/LT-31 | Condition of Sample: | Unsealed | | | |
| Source: | NA | Quantity/Type of Bottle: | 1000ml / Amber Colored Glass Bottle | | | |
| Scheme: | NA | Location/Depth: | RO plant MAA DURGAVATI PUBLIC SCHOOL, MAHUJA NEWADA, MARTINGANJ, AZAMGARH, U.P./ NA | | | |
| Village: | MAHUJA NEWADA | Habitation: | NA | | | |
| Block: - | PHOOLPUR | District: | AZAMGARH | | | |
| Latitude: | NA | Longitude: | NA | | | |
| Sample Type: Treated Water | | | | | | |
| Sr. No | Parameter | Result | As per 15-10500:2012 (2 nd Rev.) | | Unit | Reference Method: |
| | | | Acceptable Limit | Permissible Limit | | |
| 1 | pH | 7.75 | 6.5-8.5 | No Relaxation | | IS 3025 (Part 11-1993) Electrometric Method |
| 2 | Colour | 01 | 5 | 15 | Hazen | IS 3025(Part 4-2021) Visual Comparison Method |
| 3 | Odour | Agreeable | Agreeable | Disagreeable | | IS 3025 (Part 5 -2018) (Second Revision) |
| 4 | TDS | 280 | 500 | 2000 | mg/l | IS 3025 (Part 16-1984) Gravimetric Method |
| 5 | Turbidity | 0.19 | 1 | 5 | NTU | IS 3025 (Part 10-1984) Nephelometric Method |
| 6 | Alkalinity | 12 | 200 | 600 | mg/l | IS 3025 (Part 23-1986) Indicator Method |
| 7 | Hardness | 120 | 200 | 600 | mg/l | IS 3025 (Part 21-2019) EDTA Method |
| 8 | Calcium | 27 | 75 | 200 | mg/l | IS 3025 (Part 40-1991) EDTA Titrimetric Method |
| 9 | Magnesium | 13 | 30 | 100 | m\$/l | APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method |
| 10 | Chloride | 88 | 250 | 1000 | mg/l | IS 3025 (Part 32-1988) Argentometric Method |

This Report is issued under the following terms & Condition:

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed)
5. * Value not available or test not performed for this parameter.


Dr. Rajendra Prasad
Quality Manager
Authorized Signatory
For, Regional Water Analysis,
Laboratory Jan Nigam Varanasi – UP.

End of the Test Report

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 161/24-25 Dated: 25/04/2024
It is certified that an inspection team headed by ...M.H. Dr. Ayush Singh & Soma ...
(Name of Officers with designation) from ...MOI - PHC ... PHED
inspected the ...Maq Durgavati Public School, Mahuja, Newada ...
(Name & Address of the school) on ...25/04/24 ... (date of inspection) and on the basis of
Water Test Report (Attached) bearing no. ...RWTL/331/LT-31 ... dated ...24/04/24
of ...Regional Water testing Lab. Azamgarh ... (PHED Lab) certified that
the ...Maq Durgavati Public School ... (Name of school) has safe drinking water
facilities for the students and members of staff of the institution. School is also maintains the
hygienic sanitation condition in the school building & the campus as per norms prescribed by the
Central/ State/ U.T. Govt.

This certificate is valid till ...Six Month

प्रधारी चिकित्साधिकारी
सामुदायिक स्वास्थ्य केन्द्र
शाहगढ़
25/04/24
Signature with Seal: ...
Name: ...Dr. Ayush Singh ...
Designation: ...MOI - PHC ...
Name & Address of the Office / Department : ...

To ...The Manager & Principal ...
(Name & Address of the Institution)
Maq Durgavati Public School

Martingaul
PHC AzM

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies